

PROSSER VILLAGE WELL EMERGENCY/STANDBY GENERATOR PURCHASE

Addendum # 1

This Addendum No. 1 consists of 2 (8 ½ x 11) pages. It is the responsibility of Bidder to assure and guarantee by acknowledging the receipt of this Addendum that the Bidder has received the addendum in its entirety and that the Bidder accepts all conditions contained herein. **Acknowledge this addendum by including a signed copy of this Addendum in your bid submittal.**

1. Replace Page 11, "Bid Schedule", with the attached revised Bid Schedule:
2. On Page 16 of Technical Specifications, replace the first paragraph under "C. Capacities and Characteristics:" with the following:
 - "1. Power Output Ratings: Electrical output power rating for Standby operation of not less than 250 kw, at 80 percent lagging power factor, 277/480, Series Wye, Three phase, 4 -wire, 60 hertz."

No. 1: _____ signed _____ dated _____

PROSSER VILLAGE WELL EMERGENCY/STANDBY GENERATOR PURCHASE

REVISED BID SCHEDULE

DESCRIPTION
UNIT COST (FOB TRUCKEE) Tax not included

EMERGENCY / STANDBY POWER SYSTEMS
(GENERATOR SET)

QUANTITY UNITS	DESCRIPTION	Unit Cost (FOB Truckee) Tax Not Included	TOTAL
1 (ONE)	250kw, 277/480 volt, Series Wye, 3 phase, Diesel Generator Set for Prosser Village Well, located in Nevada County, CA.		

DELIVERY DATE

If the bid is awarded to me, I will deliver the generator within _____ calendar days after receiving notice of the award of bid.

Proposal submitted by:

Signature, Title and Date

Name, address, and phone number of bidder
