

PROSSER VILLAGE WELL EMERGENCY/STANDBY GENERATOR PURCHASE

Addendum # 2

This Addendum No. 2 consists of 1 (8 ½ x 11) page. It is the responsibility of Bidder to assure and guarantee by acknowledging the receipt of this Addendum that the Bidder has received the addendum in its entirety and that the Bidder accepts all conditions contained herein. **Acknowledge this addendum by including a signed copy of this Addendum in your bid submittal.**

1. On Page 26 of the Technical Specifications, replace paragraph 3.4, “Service and Support”, with the following:

“3.4 SERVICE AND SUPPORT

- A. The generator set supplier shall maintain service parts inventory for the entire power system at a central location which is accessible to the service location 24 hours per day, 365 days per year. The inventory shall have a commercial value of \$500,000 or more. The manufacturer of the generator set shall maintain a central parts inventory to support the supplier, covering all the major components of the power system, including engines, alternators, control systems, paralleling electronics, and power transfer equipment.
- B. The generator set shall be serviced by a local service organization that is trained and factory certified in generator set service. The supplier shall maintain an inventory of critical power system replacement parts in the local service location. Service vehicles shall be stocked with critical replacement parts. The service organization shall be on call 24 hours per day, 365 days per year. The service organization shall be physically located within 125 miles of the site.
- C. The manufacturer shall maintain model and serial number records of each generator set provided for at least 20 years.”

No. 2: _____ signed _____ dated