

**ASPHALT MAINTENANCE SEAL AND STRIPE 2025
CLARIFYING RESPONSES NO. 4**

This Clarifying Response NO. 4 consists of 1 pages (1 - 8.5" x 11"). It is the responsibility of the proposer to assure and guarantee that the proposer has received the response in its entirety, and that they accept all conditions contained herein.

1. **Question:** To be clear, this is for a parking lot seal coat not slurry seal correct?

Answer: The scope of services for the asphalt maintenance work to be performed are crack fill, gap fill, and (two coat application) asphalt pavement coating as outlined in the Asphalt Maintenance Seal and Stripe Contract 2025, Section 01010 – Summary of Work on pages Section 010101-1 and Section 01010-2 of the bid documents.