

**ASPHALT MAINTENANCE SEAL AND STRIPE 2025
CLARIFYING RESPONSES NO. 5**

This Clarifying Response NO. 5 consists of 1 pages (1 - 8.5" x 11"). It is the responsibility of the proposer to assure and guarantee that the proposer has received the response in its entirety, and that they accept all conditions contained herein.

1. Question: Is pressure washing a requirement for site preparation?

Answer: Contractor is responsible for all surface preparation as outlined in Section 01010-1 – SUMMARY OF WORK.

o **Surface Preparation:** The Contractor shall be responsible for all surface preparation, including the removal of vegetation from cracks and the asphalt surface, sweeping, and cleaning, **and including pressure washing of all asphalt to which an overlay is to be applied.** Contractor will be responsible for placing construction covers on all utility vaults, lids, covers prior to applying slurry.